

Coastside County Water District
Monthly Leak Report
February 2010

| Date | Location | City | Pipe Type/Size | Repair Material | Estimated Water Loss (gallons) | Repair Material Costs | Manpower and Equipment Costs | Estimated Cost of Repair (dollars) |
|--------------|--------------------------|-------------|-----------------------|---|---|----------------------------------|---|---|
| 05-Feb-10 | 490 Wavecrest | HMB | 2" galv. Main | 2"x12" full circle / 3 tons rock | 3,500 | \$155.92 | \$750 | \$906 |
| 10-Feb-10 | Francisco @ Santiago | EG | 3/4" blue plastic | 20' 3/4" copper / 1 - 3/4" angle stop / 1 - 3/4" copxcop / 2 tons rock | 600 | \$166.52 | \$750.00 | \$917 |
| 18-Feb-10 | Ave. Granada @ Solano | EG | 1" black plastic | 40' - 1" copper / 1 - copxcop / 2" - 1" reducer / 6" - 2" copper threaded / 1" copper nut | 600 | \$391.59 | \$2,200 | \$2,592 |
| 19-Feb-10 | 338 Coronado | EG | 1" black plastic | 1' - 1" copper / 1' copxcop / 1" cop nut | 1,100 | \$86.55 | \$750 | \$837 |
| TOTAL | | | | | 4,700.00 | 800.58 | 3,700.00 | 5,250.58 |