

**Coastside County Water District**  
**Monthly Leak Report**  
 July 2010

<b>Date</b>	<b>Location</b>	<b>City</b>	<b>Pipe Type/Size</b>	<b>Repair Material</b>	<b>Estimated Water Loss (gallons)</b>	<b>Repair Material Costs</b>	<b>Manpower and Equipment Costs</b>	<b>Estimated Cost of Repair (dollars)</b>
04-Jul-10	Grandview Blvd.	HMB	2" black plastic	10 ft 2" copper / 2 - 2" copxcop / 12 ton rock	42,000	\$443.94	\$2,800	\$3,244
07-Jul-10	Miramonte	HMB	6" welded steel	1 plug	3,500	\$10.00	\$750.00	\$760
07-Jul-10	Carter Hill	HMB	14" DI	Andreini hit intake pipe to Nunes. Responsible for repair	80,000	\$0.00	\$0	\$0
09-Jul-10	Laurel Ave	HMB	1" black plastic	4' - 1" copper / 1 - 1" copxcop / 1 - 1" comp nut / .5 ton rock	1,100	\$73.39	\$600	\$673
29-Jul-10	346 Coronado	EG	1" black plastic	7' - 1" copper / 1 - 1" copxcop / 1 - 1" 90 comp / 1 - 1" comp nut	1,100	\$93.68	\$700	\$794
<b>TOTAL</b>					<b>125,500.00</b>	<b>621.01</b>	<b>3,550.00</b>	<b>5,471.01</b>